

## **Declaration of Test Results**

BSI hereby declares that the item described below has been tested by BSI and complies with the requirements of

BS EN/IEC 61386-23:2004 Clauses 7.6, 8.2, 9.1, 10.5, 10.7, 13.1.3, 14.1 and 14.2.2.2

The complete detail of the tests performed and the results are recorded in BSI Test Report No: 286/7440063 Issue 3 Dated: 05 January 2010

## Description of item tested

15 off 20mm diameter lengths of flexible steel conduits (COT-KSM19-BSH) with end fittings (COT-HND142 and COT-B220NF/NM)

15 off 25mm diameter lengths of flexible steel conduits (COT-KSM25-BSH) with end fittings (COT-HND142, COT-B401 and COT-B225NF/NM)

15 off 20mm diameter lengths of (ST) flexible PVC coated steel conduits (COT-KSPS20-BSH) with end fittings (COT-HND142 and COT-B220NF/NM)

15 off 25mm diameter lengths of flexible PVC coated steel conduits (COT-KSPS25-BSH) with end fittings (COT-HND142, COT-B401 and COT-B225NF/NM)

Submitted by:

Many Folk Enterprises Limited Flat F, 13/F, Golden Plaza 745-7 Nathan Road Kowloon Hong Kong

Declaration authorised by:

JR2353a\_

Title Principal Engineer

Date 05 January 2010

Attention is drawn to the conditions upon which this declaration is issued, namely:

- This declaration does not indicate provide or imply any measure of Approval, Certification, Supervision, Control or Surveillance by BSI to this or any related product.
- This Declaration applied only to the particular sample tested and to the specific tests carried out as detailed in the Report referred to above.
- The general and specific conditions of the BSI, CP0322 apply in all respects. Copies of this leaflet are available on request.